

Description

for

WRF07 BACnet MS/TP

Index of Changes

Revision	Date	Description
A	29.07.2019	First release

Index of Changes.....	1
1 WRF07 BACnet MSTP	3
1.1 Hardware Installation	3
1.2 RS485 Transceiver	3
1.3 Protocol.....	3
1.4 Configuration Options.....	3
1.5 Dip switch and LED.....	4
1.6 Controller	5
1.6.1 Device Types	5
1.6.1 Function Mode of PI-Controller.....	5
1.6.1 Change-Over Operation.....	5
1.6.1 Energy Stop / Dew Point Detector.....	5
1.6.2 Override of Outputs.....	5
1.6.1 Minimal Control Variable.....	6
1.6.1 Calculating Set Points:	6
1.6.2 Function 6WV for BELIMO® 6-way valves	7
1.6.3 Function 6WV for SAUTER 6-way valves DN15 und DN20	7
1.7 LED- and Button-Mapping.....	9
2 Description BACnet Objects.....	9
2.1 Device Object	9
2.2 Analog Inputs	10
2.3 Binary Inputs	10
2.4 Analog Values.....	11
2.5 Binary Values.....	11
2.6 Multistate Values	12
2.7 Analog Outputs	13
2.8 Binary Outputs	14
3 BACnet PICS	14
4 BACnet BIBBs	15

1 WRF07 BACnet MSTP

The present document describes the BACnet-Objects of the room operating panel WRF07 BACnet MS/TP.

1.1 Hardware Installation

The room operating panel can be connected by means of a twisted-pair cable (line resistance 120 Ohm). For detailed information on installation and mounting, please see the product datasheet.

1.2 RS485 Transceiver

The maximal number of bus participants without the use of a repeater is default by the RS485 transceiver. The transceiver used in the device enables 32 devices per bus segment.

1.3 Protocol

The protocol used is the internationally standardized BACnet MS/TP protocol. This allows the connection to corresponding counterparts, e.g. an automation station or a BMS that supports the BACnet MS / TP protocol. The transmission parameters are set to 8N1 (8 data bits, no parity, 1 stop bit) according to the standard.

The baud rate is freely selectable and can be set via dip switch.

1.4 Configuration Options

The device can be adapted to the corresponding bus topology by means of a dip switch.

- MAC-Address of the device (1 - 127)
- Baud rate 9600, 19200, 38400, 57600, 76800 or 115200

1.5 Dip switch and LED

LEDs




Via the integrated LEDs the current operating status of the BACnet interface is indicated.

LED	Meaning
STA	Blinks during normal operation Lights up permanently during sensor initialization of device start
RXD	Blinks when RS485 BACnet telegrams are received
TXD	Blinks when RS485 BACnet telegrams are sent
ERR	Lights up in case of a corrupt bus configuration and internal errors

Note: During start-up, all 4 LEDs flash for a few seconds.

Dip Switch



Example: MAC-Address 119, 57600 Baud

MAC-Address

Dip switch	1	2	3	4	5	6	7
Value	2^0 (1)	2^1 (2)	2^2 (4)	2^3 (8)	2^4 (16)	2^5 (32)	2^6 (64)

Baudrate

8	9	10	Baudrate
off	off	off	9600
on	off	off	19200
off	on	off	38400
on	on	off	57600
off	off	on	76800
on	off	on	115200
off	on	on	
on	on	on	

1.6 Controller

1.6.1 Device Types

The controller is integrated in the following devices: AO2V, OVR, OVT, DO2R, DO2T, 6WV.

1.6.2 Function Mode of PI-Controller

The integrated PI-controller controls the temperature of set point. The control variable resulting is directly output to the outputs. The PI-controller can be set by properties. The control variable of the controller is re-calculated approx. every second.

1.6.3 Change-Over Operation

The device can be used for a 2-pipe and a 4-pipe wire system. The corresponding selection is made via the BACnet objects BV-112.

If the change-over operation is activated, the corresponding mode (heating or cooling of controller) must be defined via MV-0.

The Change-Over Operation runs via output 1.

1.6.4 Energy Stop / Dew Point Detector

If a window contact or a dew point detector are connected to the digital inputs and the digital inputs are parameterized the same, both are directly affecting the control.

1.6.5 Override of Outputs


During operation an overriding of the outputs is possible via the BACnet objects AO-0 and AO-1. The automatic mode of an output is activated if the corresponding value is -1. In automatic mode, the output is directly linked to the manipulated variable of the controller.

1.6.6 Minimal Control Variable

Via the BACnet object BV-111 can be selected whether the minimal control variable is only used, if the control variable is > 0 .


Mode Selection Control Variable

- (1) Mode selection Control Variable > 0
 $Y_{min} = 20\%$



The control variable is only sent to the output if the calculated value of the control variable is bigger than the minimal control variable.

- (1) Mode selection Control Variable $= 0$
 $Y_{min} = 20\%$



The minimal control variable at the output remains unchanged until the controller changes the operating mode

1.6.7 Calculating Set Points:

(1) OCCUPIED

- Heating set point = basic set point + offset + poti offset*
- Cooling set point = basic set point + dead zone + offset + Poti-Offset*

(2) UNOCCUPIED


- Heating set point = basic set point + offset + poti offset* -night lowering
- Cooling set point = basic set point + dead zone + offset + poti offset* + night lowering

*if used

1.6.8 Function 6WV for BELIMO® 6-way valves

If device type "6WV" (for BELIMO® 6-way valves) is enabled, output AO1 is used as control variable output for 6-way valve. Control variable is calculated by integrated PI controller and the output voltage is adapted according to characteristic curve of used device type. Choosing type 6WV_INV inverts sequences for heating and cooling.


100...0% cooling \Rightarrow 2,0...4,7V
 0...100% heating \Rightarrow 7,3...10,0V



1.6.9 Function 6WV for SAUTER 6-way valves DN15 und DN20


If device type „6WV_DN15“, or „6WV_DN20“ (for SAUTER 6-way valves) is enabled, output AO1 is used as control variable output for 6-way valve. Control variable is calculated by integrated PI controller and the output voltage is adapted according to characteristic curve of used device type. Please see SAUTER datasheet 58.001, B2KL: 6-way-ball valve with male thread, PN16).

Circuit B2KL015F400




Picture 1 Charactersitic curve of DN15 valve (extract from SAUTER datasheet 58.001e)

Circuit B2KL020F400



Picture 2 Charactersitic curve of DN20 valve (extract from SAUTER datasheet 58.001e)

1.7 LED- and Button-Mapping



2 Description BACnet Objects

2.1 Device Object

Property	Access	Range	Default
Object Identifier (Device ID)	R	0...4194302	Device Offset ID + MAC-Address
Object Name	R		DeviceID_ModelName Example: "123_WRF07 BACnet MSTP"
Object Type	R		Device
Description	RW	Max. 32 characters	
Location	RW	Max. 32 characters	
System Status	R		Operational
Vendor Name	R		Thermokon Sensortechnik GmbH
Model Name	R		WRF07 BACnet MSTP
Protocol Version	R		1
Protocol Revision	R		12
Max. APDU Length	R		480
Segmentation Support	R		no
APDU Timeout	R		3000 ms
Number APDU Retries	R		3
Max Masters	R		127
Max Info Frames	RW		1

2.2 Analog Inputs

Object	Description	
AI-0	Temperature	°C / °F
AI-1	Relative Humidity	%rF
AI-2	Absolute Humidity	g/m³ / gr/ft³
AI-3	Enthalpy	kJ/kg / BTU/lbs
AI-4	Dewpoint	°C / °F
AI-5	Setpoint Absolute	°C / °F
AI-6	Setpoint Adjustment	°C / °F
AI-7	PI-Controller Mode	1 = off 2 = heating 3 = cooling 4 = AUTO heating 5 = AUTO cooling
AI-8	PI-Controller Y Heat	0...100%
AI-9	PI-Controller Y Cool	
AI-10	Output 1 Value	0...10V
AI-11	Output 2 Value	
AI-12	Digital Input 1 Counter	After read out, this value will be set to 0.
AI-13	Digital Input 2 Counter	
AI-14	Digital Input 3 Counter	
AI-15	Digital Input 4 Counter	

2.3 Binary Inputs

Object	Description	
BI-0	Occupancy	0: unoccupied 1: occupied
BI-1	Button 1	0: released 1: pressed
BI-2	Button 2	
BI-3	Button 3	
BI-4	Button 4	
BI-5	Button 5	
BI-6	Button 6	
BI-7	Button 7	
BI-8	Button 1 (saved)	0: released 1: pressed The information will saved until next read out.
BI-9	Button 2 (saved)	
BI-10	Button 3 (saved)	
BI-11	Button 4 (saved)	
BI-12	Button 5 (saved)	
BI-13	Button 6 (saved)	
BI-14	Button 7 (saved)	
BI-15	Switch Position 1	0: released 1: pressed
BI-16	Switch Position 2	0: released 1: pressed The information will saved until next read out.
BI-17	Switch Position 1 (saved)	
BI-18	Switch Position 2 (saved)	0: false 1: true
BI-19	Digital Input 1	
BI-20	Digital Input 2	0: false 1: true The information will saved until next read out.
BI-21	Digital Input 3	
BI-22	Digital Input 4	
BI-23	Digital Input 1 (saved)	
BI-24	Digital Input 2 (saved)	
BI-25	Digital Input 3 (saved)	
BI-26	Digital Input 4 (saved)	

2.4 Analog Values

Object	Description	
AV-0	Setpoint Adjustment Range	-100 ... +100 °C / °F
AV-1	Base Setpoint	-100 ... +100 °C / °F
AV-100	Offset Device ID	Offset Device ID + MAC = Device ID
AV-101	Temperature Offset	-20 ... +20 °C / °F
AV-102	Rel. Humidity Offset	-10 ... +10 %rF
AV-103	Base Setpoint after Reset	-100 ... +100 °C / °F
AV-104	Setpoint Adjustment Range After Reset	-100 ... +100 °C / °F
AV-105	Setpoint Unoccupied Adjustment	-100 ... +100 °C / °F
AV-106	Occupancy Party Time	0 ... 86400 s (0...24 h)
AV-107	PI-Ctr. Dead Band	0 ... 100 °C / °F
AV-108	PI-Ctr. xp Heat	0 ... 100 °C / °F
AV-109	PI-Ctr. Tn Heat	0 ... 100 Min.
AV-110	PI-Ctr. Y-min Heat	0 ... 100%
AV-111	PI-Ctr. Y-max Heat	0 ... 100%
AV-112	PI-Ctr. PWM-cycle Heat	0 ... 10800 s (0...3 h)
AV-113	PI-Ctr. xp Cool	0 ... 100 °C / °F
AV-114	PI-Ctr. Tn Cool	0 ... 100 Min.
AV-115	PI-Ctr. Y-min Cool	0 ... 100%
AV-116	PI-Ctr. Y-max Cool	0 ... 100%
AV-117	PI-Ctr. PWM-cycle Cool	0 ... 10800 s (0...3 h)
AV-118	PI-Ctr. Frost Protection	0 ... 100 °C / °F
AV-119	Fan Stage 1 Threshold Y Heat	0 ... 100% Depending on the control variables of the PI controller for heating / cooling, the fan levels are activated according to the threshold values.
AV-120	Fan Stage 2 Threshold Y Heat	
AV-121	Fan Stage 3 Threshold Y Heat	
AV-122	Fan Stage 1 Threshold Y Cool	
AV-123	Fan Stage 2 Threshold Y Cool	
AV-124	Fan Stage 3 Threshold Y Cool	0 ... 10V
AV-125	Fan Stage 1 Output Voltage	
AV-126	Fan Stage 2 Output Voltage	
AV-127	Fan Stage 3 Output Voltage	

Note: The objects starting from AV-100 are configuration parameters that retain the values even after a restart.

2.5 Binary Values

Object	Description	
BV-0	PI-Ctr. Energy Hold Off	0: false 1: true
BV-1	PI-Ctr. Enable	0: false 1: true
BV-2	PI-Ctr. Dewpoint	0: false 1: true
BV-3	Occupancy Override	0: unoccupied 1: occupied
BV-100	Unit-System	0: Imperial 1: SI
BV-101	COV Enable - Temperature	0: disable 1: enable
BV-102	COV Enable - rel. Humidity	
BV-103	COV Enable - abs. Humidity	
BV-104	COV Enable - Enthalpy	
BV-105	COV Enable - Dewpoint	
BV-106	COV Enable - Setpoint	
BV-107	COV Enable - Occupancy	
BV-108	COV Enable - Buttons	
BV-109	COV Enable - Switch	
BV-110	COV Enable - Inputs	

BV-111	PI-Ctr. Y-Min. if Y>0	0: false 1: true
BV-112	PI-CTR. Change Over	0: false 1: true
BV-113	Occupancy after Reset	0: unoccupied 1: occupied

Note: The objects starting from BV-100 are configuration parameters that retain the values even after a restart.

2.6 Multistate Values

Object	Description	
MV-0	PI-Ctr. Mode Override	off heat cool automatic
MV-1	Fan Stage	Stage 0 (Fan OFF) Stage 1 (manual) Stage 2 (manual) Stage 3 (manual) automatic
MV-100	Device Type	AO2V (AO1: heat, AO2: cool)
		DO2R (DO1: heat, DO2: cool)
		DO2T (DO1: heat, DO2: cool)
		OVR (DO1: heat, AO2: cool)
		OVT (DO1: heat, AO2: cool)
		4DI (4 digitale Eingänge)
		6WV For BELIMO® 6-Wegeventil, (AO1: 2...4,7V cool, 7,3...10V heat)
		6WV_INV For BELIMO® 6-Wegeventil, (AO1: 2...4,7V heat, 7,3...10V cool)
		6WV_DN15 Für SAUTER 6-Wegeventil DN15
		6WV_DN20 Für SAUTER 6-Wegeventil DN20
MV-101	PI-Ctr. Mode after Reset	off heat cool automatic
MV-102	Setpoint Visualization	Always Heat-Setpoint Heat- and Cool-Setpoint
MV-103	Button 1 Function	Contact
MV-104	Button 2 Function	Pulse Unoccupied
MV-105	Button 3 Function	Pulse Occupied
MV-106	Button 4 Function	Toggle Occupancy
MV-107	Button 5 Function	Contact Occupied
MV-108	Button 6 Function	Pulse Party Time
MV-109	Button 7 Function	Fan Stage UP
MV-110	Button 8 Function	Fan Stage DOWN
MV-111	Button 9 Function	Fan Stage Loop (0, 1, 2, 3, Auto, 0, 1, ...)
MV-112	LED 1 Function	Bus Controlled

MV-113	LED 2 Function	Occupancy
MV-114	LED 3 Function	PI Controller Active
MV-115	LED 4 Function	PI Controller Heating
MV-116	LED 5 Function	PI Controller Cooling
MV-117	LED 6 Function	Fan Stage 0
MV-118	LED 7 Function	Fan Stage 1
MV-119	LED 8 Function	Fan Stage 2
MV-120	LED 9 Function	Fan Stage 3
		Fan AUTO
MV-121	Input 1 Function	NC Contact
MV-122	Input 2 Function	NC Dewpoint
MV-123	Input 3 Function	NC Window
MV-124	Input 4 Function	NC Occupancy
		NC PI Ctr. Auto/Off
		NC PI Ctr. Heat/Cool
		NO Contact
		NO Dewpoint
		NO Window
		NO Occupancy
		NO PI Ctr. Auto/Off
		NO PI Ctr. Heat/Cool
MV-125	Input 1 Counter Mode	Edge Pulse
MV-126	Input 2 Counter Mode	
MV-127	Input 3 Counter Mode	
MV-128	Input 4 Counter Mode	
MV-129	Number of Fan Stages	0 (Fan OFF) 1 (manual) 2 (manual) 3 (manual) 0 (Fan OFF) 1 (automatic) 2 (automatic) 3 (automatic)
MV-130	Fan Stage after Reset	0 (Fan OFF) 1 (manual) 2 (manual) 3 (manual) automatic
MV-131	Min. Fan Stage	0 1 2 3

Note: The objects starting from MV-100 are configuration parameters that retain the values even after a restart.

2.7 Analog Outputs

Object	Description	
AO-0	Output 1 Value Override	0...10 V
AO-1	Output 2 Value Override	(-1 disables the override function)

2.8 Binary Outputs

Object	Description	
BO-0	LED 1	False = LED off True = LED on
BO-1	LED 2	
BO-2	LED 3	
BO-3	LED 4	
BO-4	LED 5	
BO-5	LED 6	
BO-6	LED 7	
BO-7	LED 8	
BO-8	LED 9	

3 BACnet PICS

BACnet Protocol Implementation Conformance Statement

Date:	04.04.2019
Vendor Name:	Thermokon Sensortechnik GmbH (Vendor ID: 396)
Product Names:	WRF07 BACnet MSTP
Firmware Revision:	1.0.0
Application Software Version:	1.0.0
BACnet Protocol Revision:	1.12
Product Description:	Sensor device with BACnet MS/TP RS485 interface.
BACnet Standardized Device Profile:	BACnet Smart Sensor (B-SS)

4 BACnet BIBBs

Supported BIBBS	BIBB Name
DS-RP-B	Data Sharing, Read Property, B
DS-RPM-B	Data Sharing, Read Property Multiple, B
DS-WP-B	Data Sharing, Write Property, B
DS-COVU-B	Data Sharing, COV Unsubscribed, B
DM-DOB-B	Device Management, Dynamic Object Binding, B
DM-DCC-B	Device Management, Device Communication Control, B
DM-DDB-B	Device Management, Dynamic Device Binding, B

BACnet Standard Application Services Supported:

ReadProperty
 ReadPropertyMultiple
 WriteProperty
 DeviceCommunicationControl
 WhoHas
 Whols

Standard Object Types Supported:

Object-Type	Dynamically Creatable Deleteable	Optional Properties supported	Writable Properties
Binary Input	No	Description, COV Increment	
Binary Value	No	Description	Present Value
Binary Output	No	Description	Present Value
Analog Input	No	Description, COV Increment	COV Increment
Analog Value	No	Description	Present Value
Analog Output	No	Description	Present Value
Multistate Values	No	Description	Present Value
Device	No	Description	Description

Data Link Layer Option:

MS/TP master. Baud rate(s): [9600, 19200, 38400, 57600, 76800, 115200]

Device Address Binding:

Is static device binding supported?

Yes

☐

No

☒

Character Sets Supported:

UTF-8

Special Functionality:

Maximum APDU size in octets: 480